

Certificate

Registration No.: PV 50194626

Page 1

Report No.: 15040312.001

License Holder:

SIMAX (SUZHOU) GREEN NEW ENERGY CO.,LTD
 Beibanjing riverside, Suzhou Road,
 Taicang City, 215400,
 P.R. China

Product:

PV Module
 Type:
 SM596-xxx (xxx=220 to 260, increment 5)
 SM572-xxx (xxx=165 to 195, increment 5)
 SM536-xx (xxx=85 to 95, increment 5)
 SM672-xxx (xxx=255 to 300, increment 5)
 SM660-xxx (xxx=210 to 250, increment 5)
 SP672-xxx (xxx=250 to 300, increment 5)
 SP660-xxx (xxx=210 to 250, increment 5)
 SP654-xxx (xxx=185 to 220, increment 5)
 SP636-xxx (xxx=125 to 145, increment 5)

Manufacturing Plant:

SIMAX (SUZHOU) GREEN NEW ENERGY CO.,LTD
 Beibanjing riverside, Suzhou Road,
 Taicang City, 215400,
 P.R. China

Basis:

- IEC 61730-1:2004
 IEC 61730-2:2004
 EN 61730-1:2007
 EN 61730-2:2007
 "Photovoltaic (PV) module safety qualification"
- Factory Inspection**
 To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 15040310.001.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 28 December 2015.

Certification body



Shanghai, 29 December 2010

Dipl.-Ing. Bernd Scheirer

TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg
 Contact: + (+49) 221 606-1371 email: cert-validity@de.tuv.com